



FLOOR PLAN
 CONVECTION E-020 1:25
 VIEW FROM BELOW
 E020-B

MARK	POS.	QUANT.	DENOMINATION	LENGTH.	MATERIAL	WEIGHT Kg.	NOTES	MARK	POS.	QUANT.	DENOMINATION	LENGTH.	MATERIAL	WEIGHT Kg.	NOTES
E020-B	14	1	PL. 273x5	12276	S275 JR	131.5		60	8	IPE100	400	S275 JR	25.9		
	15	2	PL. 200x15	260	S275 JR	12.3		61	4	PL. 120x10	2860	S275 JR	107.8		
	22	2	PL. 690x12	960	S275 JR	124.8		62	3	PL. 200x15	210	S275 JR	14.8		
	23	4	PL. 520x12	690	S275 JR	135.2		63	6	PL. 100x10	1015	S275 JR	47.8		
	28	12	PL. 250x10	425	SS310	100.1		64	1	PL. 2525x5	12232	S275 JR	1212.3		
	29	36	PL. 100x10	240	SS310	67.8		65	4	PL. 220x30	890	S275 JR	184.4		
	38	20	BOLT M24x65 & NUT		GR. 8.8			66	4	PL. 76x15	200	S275 JR	7.2		
	39	40	WASHER M24		GR. 8.8			67	4	PL. 110x15	190	S275 JR	9.8		
	42	76	BOLT M20x50 & NUT		GR. 8.8			68	6	PL. 100x20	460	S275 JR	43.3		
	43	152	WASHER M20		GR. 8.8			69	12	PL. 76x15	220	S275 JR	23.6		
	50	2	UPN240	12240	S275 JR	812.7		70	12	PL. 100x15	200	S275 JR	31.1		
	51	3	HEA200	1870	S275 JR	237.3		71	6	PL. 280x2	425	SS304	22.4		
	52	6	PL. 94x10	200	S275 JR	8.9		72	8	IPE100	1870	S275 JR	121.2		
	53	6	PL. 40x10	171	S275 JR	3.3		73	2	PL. 100x10	1008	S275 JR	15.8		
	54	3	HEA200	395	S275 JR	50.1		74	4	PL. 100x10	1016	S275 JR	31.9		
	55	3	PL. 93x10	200	S275 JR	4.5		75	4	PL. 475x12	690	S275 JR	124.8		
	56	3	PL. 50x10	146	S275 JR	1.8							3864.9		
	57	2	UPN240	1870	S275 JR	124.2								kg. 3865	
	58	1	UPN240	395	S275 JR	13.1									
	59	1	UPN240	395	S275 JR	13.1									

"Y" TYPE ANCHOR DOUBLE LAYER LINING (F.S.)
 TYP. FOR INTERNAL PLATE CONVECTION
 SEE "REFRACTORY STD" - "STD-004"
 (REFRACTORY 175+75=250)

PROJ.: 30598 - INA HGU RIJEKA
 CLIENT: INA INDUSTRIJA NAFTE d.d.

MR N°: 0131-02
 PO N°: 30598/A0016

ITEM: -
 VR Doc. CODE: -

VENDOR DOCUMENT REVIEW

1 REVISE AND RESUBMIT
 2 TO BE ISSUED AS FINAL PROVIDED COMMENTS ARE INCORPORATED
 3 NO COMMENT - FINAL ISSUE

4 FOR INFORMATION ONLY (INTERNAL ISSUE)

U.O.: TECHNIP KTI S.p.A.
 BY: _____ DATE: _____

2	ISSUED FOR CONSTRUCTION	20.10.08	R.VITALBA	A.PALMISANO	A.QUERO
1	REVISED I.A.W. CLIENT REV.	25.08.08	R.VITALBA	A.PALMISANO	A.QUERO
0	ISSUED FOR APPROVAL	05.08.08	R.VITALBA	A.PALMISANO	A.QUERO

CLIENTE : INA INDUSTRIJA NAFTE d.d.
 PROGETTO : 30598 - INA HGU RIJEKA
 LOCALITA' : RIJEKA

COMM 08/965
 ITEM E-020
 N° FABBR. 507

SERVICE :
 E-020 CONVECTION SECTION
 MARK E020-B - PLAN

NUMERO DISEGNO
 08965-A-002

SCALA 1:25

TECNOMIEC
 Technic plants, maintenance, engineering
 TARANTO (ITALY) www.tecnomec-engit

FOGLIO 1 DI 3